



Tech Note 071014_01

Date: July 10, 2014
Product: Aperio Platform
Subject: Hardware reset of Device Instance Number
Note: Procedure

1. Turn the Controller Board Power Switch "Off".
2. Set the Network Address Rotary Switches to "00".
3. Turn the Controller Board Power Switch "On", wait 15 seconds.
4. Turn the Controller Board Power Switch "Off".
5. Set the Network Address Rotary Switches to the appropriate address.
6. Turn the Controller Board Power Switch "On", wait 15 seconds.
7. The Device Instance Number will now be set to "1320XX" followed by the Rotary Address (XX).

