

Blue Ridge Technologies : Contractor Responsibility Guide

System Equipment	Division 25				Division 26			
	Furnish	Install	Wire	Note	Furnish	Install	Wire	Note
Centralized Panels (Switching or Dimming)	X					X	X	Tag / label device as required
Distributed Controllers (Switching or Dimming)	X					X	X	Tag / label device as required
Satellites (Switching or Dimming)	X					X	X	Tag / label device as required
Contactors	X					X	X	Tag / label device as required
Low Voltage Field Device - Wall Switch or Key Switch	X					X	X	Tag / label device as required
Low Voltage Field Device - Addressable Stations	X					X	X	Tag / label device as required
Low Voltage Field Device - 24VDC Occupancy Sensors	X					X	X	Tag / label device as required. Set timer to min. or zero. Set coverage pattern. Coordinate location with Div 25
Low Voltage Field Device - 24VDC Light Level Sensors (Indoor, Outdoor, or Daylight)	X					X	X	Tag / label device as required. Coordinate location with Div 25
Low Voltage Field Device - Faceplates					X	X		Engrave / label as required
System Warranty	X							
System Installation Warranty					X			

System Infrastructure	Division 25				Division 26			
	Furnish	Install	Wire	Note	Furnish	Install	Wire	Note
BACnet Network (Conduit and Raceway)					X	X		Pullstring
BACnet Network (Wire and Terminations)	X	X	X	Address Device				
Line Voltage (Class I) Between Circuit Breaker and Lighting Controller and Lighting Load (Conduit, Raceway, Wire, and Terminations)					X	X	X	All 0-10V Signal wires shall be wired as Class I
Low Voltage (Class II) between Lighting Controller and Low Voltage Field Devices (Conduit, Raceway, Wire, and Terminations)				Address Stations and Satellites	X	X	X	All 0-10V Signal wires shall be wired as Class I

System Engineering	Division 25				Division 26			
	Furnish	Install	Wire	Note	Furnish	Install	Wire	Note
Submittal Package and As-built Drawings	X			Provide Div 26 with drawings	X			Provide Div 25 mark-ups for As-built
Sequence of Operations	X	X						
Operators Interface	X	X						
Programming and Configuration	X	X						
System Checkout & Commissioning	X				X			Be present to address items
System Demonstration and Acceptance	X				X			Be present to address items
System Training	X							