


WARNING:
Live Parts. Disconnect before servicing. Disconnect provided by installer, located remotely.
Panel Protected by circuit breaker or equivalent current limiting device.
Use only copper conductors rated only @ 60 degree celsius minimum.

Engineering Standards RISS32_02.00			
Retrofit Interior 32 Relay, Center Mount, CTS			
Rev: 4	Type:	Date: 01-20-15	Job #:
 UNIFIED LIGHTING CONTROL		Engineered: NB	
		Drawn: NB	
		Checked:	
		1 of 1	